



Compliance Statement

ISO/IEC, EN & TIA Screened Class E_A / Category 6A Two Connector Permanent Link

**Telebox Industries Corp.
4F, No. 306, Tatung Road, Sec 1
Hsichih-Taipei 221, Taiwan, R.O.C**

Compliance Statement No. 112732B

This type of Class E_A / Category 6A screened two connector permanent link has been tested by 3P Third Party Testing and complies with the 10 Gigabit Ethernet requirements of IEEE P802.3an, Class E_A requirements of Edition 2.2 of ISO/IEC 11801 and CENELEC EN 50173-1:2011, and Category 6A requirements of ANSI/TIA-568-C.2. The Compliance Statement is valid for the permanent link type in T568B designation connected with RJ 45 plugs from Telebox, P/NTA3368DS. The qualification may be suspended or withdrawn if it fails to pass a Maintenance Testing performed at 24 month intervals. The permanent link consists of the following components:

<i>Cable:</i>	<i>Horizontal Cable from Draka, Qualification Status:</i>	<i>P/N Silverline Gold 1000 Manufacturer verified</i>
<i>Conn. Hardw.:</i>	<i>Keystone Jack from Telebox, Patch Panel from Telebox: Qualification Status:</i>	<i>P/N TB806ASx having PCB Marking 001-8074 P/N LB246ASx and P/N MLB246ASx having PCB Marking Cat.6A 001-0895 Manufacturer Verified</i>

Hoersholm, 30th November 2012

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 30th November 2012

Paul Villien

Poul Villien
Coordinating Manager