



# Attestation of Conformity

## ISO/IEC, EN & TIA/EIA Screened Class E / Category 6 Permanent Link

**Telebox Industries Corporation  
4F, No. 306, Sec 1, Ta-Tung Road  
Hsi-Chih Chen, Taipei Hsien, Taiwan R.O.C**

### *Attestation of Conformity No. 103361B*

*This type of Class E / Category 6 screened permanent link has been tested by 3P Third Party Testing and complies with the Class E permanent link requirements of 2nd Edition ISO/IEC 11801 and CENELEC EN 50173-1, and the Category 6 permanent link requirements of ANSI/TIA/EIA-568-B.2-1. The Attestation of Conformity is valid for the actually tested permanent link sample in T568B designation connected to test equipment with RJ 45 plug from Telebox, P/N TA5708FS, and consisting of the following components:*

<i>Cable from Telebox:</i>	<i>Horizontal Cable,</i>	<i>P/N SS9800X in LSOH Version (Draka Norsk Kabel, type 79441X)</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>
<i>Conn. Hardw. from Telebox:</i>	<i>Keystone Jack,</i>	<i>P/N TA8668SX-XX having PCB Marking Cat.6 001-8665</i>
	<i>Patch Panel,</i>	<i>P/N LP246SXX having PCB Marking 001-0863 CAT.6</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 3 May 2003

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 3 May 2003

*Poul Villien*

Poul Villien  
Coordinating Manager